Panasonic ideas for life



DIN48 SIZE MULTI-RANGE ANALOG TIMER

UL File No.: E122222 CSA File No.: LR39291



Features

- 100-240V AC free-voltage input, 48-125V DC type available
- Short body 62.5mm 2.461 inch (screw terminal type)
- Front panel of IP65 type is protected against water-splash and dust
- Built-in Screw terminals
- Screw terminal type is used for easy wiring and reducing additional cost for accessories.
- 0 setting instantaneous output operation
- Multiple time ranges 1 s to 500 h (Max.) 8 different operation modes: (PM4H-A)
- Compliant with UL/CSA, CE and LLOYD

Product types

Туре	Operation mode	Contact arrangement	Time range	Protective construction	Rated operating voltage	Terminal type	Part number
					100 1- 0401/ 40	11 pins	PM4HA-H-AC240VW
					100 to 240V AC	Screw terminal	PM4HA-H-AC240VSW
					48 to 125V DC	11 pins	PM4HA-H-DC125VW
				IP65		Screw terminal	PM4HA-H-DC125VSW
	8 operation modes			1265	041/ 40/00	11 pins	PM4HA-H-24VW
					24V AC/DC	Screw terminal	PM4HA-H-24VSW
	 Pulse ON-delay Pulse Flicker 				101/ 00	11 pins	PM4HA-H-DC12VW
PM4H-A	Pulse ON-flicker	Relay			12V DC	Screw terminal	PM4HA-H-DC12VSW
	Differential ON/OFF-delay (1) (2)	Timed-out 2 Form C			100 to 240V AC	11 pins	PM4HA-H-AC240V
	 Signal OFF-delay Pulse One-shot 	2101110			100 10 240V AC	Screw terminal	PM4HA-H-AC240VS
	Pulse One-cycle				48 to 125V DC	11 pins	PM4HA-H-DC125V
				IP50	46 10 125 V DC	Screw terminal	PM4HA-H-DC125VS
				1250	24V AC/DC	11 pins	PM4HA-H-24V
					24V AC/DC	Screw terminal	PM4HA-H-24VS
					101/ DC	11 pins	PM4HA-H-DC12V
					12V DC	Screw terminal	PM4HA-H-DC12VS
					100 +- 0.101/ 4.0	8 pins	PM4HS-H-AC240VW
					100 to 240V AC	Screw terminal	PM4HS-H-AC240VSW
					48 to 125V DC	8 pins	PM4HS-H-DC125VW
				IDOS	48 to 125V DC	Screw terminal	PM4HS-H-DC125VSW
				IP65	041/ 40/00	8 pins	PM4HS-H-24VW
					24V AC/DC	Screw terminal	PM4HS-H-24VSW
					12V DC	8 pins	PM4HS-H-DC12VW
DI UNO		Relay	16 selectable			Screw terminal	PM4HS-H-DC12VSW
PM4H-S	Power ON-delay	Timed-out 2 Form C	ranges 1s to 500h		100 to 240V AC	8 pins	PM4HS-H-AC240V
			13 10 30011			Screw terminal	PM4HS-H-AC240VS
					48 to 125V DC	8 pins	PM4HS-H-DC125V
				1050		Screw terminal	PM4HS-H-DC125VS
				IP50	24V AC/DC	8 pins	PM4HS-H-24V
			_			Screw terminal	PM4HS-H-24VS
					12V DC	8 pins	PM4HS-H-DC12V
						Screw terminal	PM4HS-H-DC12VS
					100 to 240V AC	8 pins	PM4HM-H-AC240VW
						Screw terminal	PM4HM-H-AC240VSW
						8 pins	PM4HM-H-DC125VW
						Screw terminal	PM4HM-H-DC125VSW
				IP65		8 pins	PM4HM-H-24VW
	5 operation modes				24V AC/DC	Screw terminal	PM4HM-H-24VSW
	(With instantaneous contact)	Relay	-		101/00	8 pins	PM4HM-H-DC12VW
	Power ON-delay	Timed-out			12V DC	Screw terminal	PM4HM-H-DC12VSW
PM4H-M	 Power Flicker Power ON-flicker 	1 Form C Instantaneous				8 pins	PM4HM-H-AC240V
	Power On-shot Power One-shot Power One-cycle	1 Form C		IP50	100 to 240V AC	Screw terminal	PM4HM-H-AC240VS
						8 pins	PM4HM-H-DC125V
					48 to 125V DC	Screw terminal	PM4HM-H-DC125VS
						8 pins	PM4HM-H-24V
					24V AC/DC	Screw terminal	PM4HM-H-24VS
					12V DC	8 pins	PM4HM-H-DC12V

If you use this timer under harsh environment, please order above sealed type (IP65 type), IP65 type — Protection dust and water jet splay on the front face.

PM4H-A/S/M

Time range

Scale	Time unit	sec	min	hrs	10h
1		0.1s to 1s	0.1 min to 1 min	0.1h to 1h	1.0h to 10h
5	Control time range	0.5s to 5s	0.5 min to 5 min	0.5h to 5h	5h to 50h
10		1.0s to 10s	1.0 min to 10 min	1.0h to 10h	10h to 100h
50		5s to 50s	5 min to 50 min	5h to 50h	50h to 500h
	ie feu in stanten				

PM4H-A/PM4H-S/PM4H-M All types of PM4H timer have multi-time range. 16 time ranges are selectable. 15 to 500h (Max. range) is controlled.

Note: 0 setting is for instantaneous output operation.

Specifications

Item		Туре	PM4H-A	PM4H-S	PM4H-M		
	Rated operating volta	ige	100 to 240V AC, 48 to 125V DC, 12V DC, 24V AC/DC				
Rating	Rated frequency		50/60Hz common (AC operating type)				
	Rated power consum	ption	Approx. 10VA (100 to 240V AC) Approx. 2.5VA (24V AC) Approx. 1.5W (12V DC, 24V DC, 48 to 125V DC)				
	Rated control capacity		5A 250V AC (resistive load)				
	Operating mode		Pulse ON-delay Pulse Flicker Pulse ON-Flicker Differential ON/OFF-delay (1) (2) Signal OFF-delay Pulse One-shot Pulse One-cycle	Power ON-delay	Power ON-delay Power Flicker Power ON-flicker Power One-shot Power One-cycle (with instantaneous contact)		
	Time range		1s	to 500h (Max.) 16 time ranges switcha	ble		
Time accuracy Note:1)	Operating time fluctuation		±0.3% (power off time change at the range of 0.1s to 1h)				
	Setting error		±5% (Full-scale value)				
	Voltage error		$\pm 0.5\%$ (at the operating voltage changes between 85 to 110%)				
	Temperature error		\pm 2% (at 20°C ambient temp. at the range of –10 to +50°C +14 to +122°F)				
Contest	Contact arrangement		Timed-out 2 Form C		Timed-out 1 Form C Instantaneous 1 Form C		
Contact	Contact resistance (Initial value)		Max. 100mΩ (at 1A 6V DC)				
	Contact material		Silver alloy		Au flash on Silver alloy		
Life	Mechanical (contact)		2×10 ⁷				
Life	Electrical (contact)		10 ⁵ (at rated control capacity)				
	Allowable operating voltage range		85 to 110% of rated operating voltage (at 20°C coil temp.)				
	Insulation resistance (Initial value)		Min. 100MΩ Between live and dead metal parts Between input and output (At 500V DC) Between contacts of different poles Between contacts of same pole				
Electrical function	Breakdown voltage (Initial value)		2,000Vrms for 1 min Between live and dead metal parts 2,000Vrms for 1 min Between input and output 2,000Vrms for 1 min Between contacts of different poles 1,000Vrms for 1 min Between contacts of same pole				
	Min. power off time						
	Max. temperature rise		55°C	65°C 149°F			
	Vibration resistance	Functional	10 to 55Hz: 1 cycle/min double amplitude of 0.25mm (10min on 3 axes)				
Mechanical		Destructive	10 to 55Hz: 1 cycle/min double amplitude of 0.375mm (1h on 3 axes)				
function	Shock resistance	Functional	Min. 98m/s ² (4 times on 3 axes)				
		Destructive	Min. 980m/s ² (5 times on 3 axes)				
	Ambient temperature		-10 to +50°C +14 to +122°F				
Operating	Ambient humidity		30 to 85%RH (at 20°C 68°F, non-condensing)				
condition	Atmospheric pressure		860 to 1,060hPa				
	Ripple factor (DC typ	,	20%				
Others	Protective construction	on	IP65 on front panel (using rubber gasket ATC18002) <only for="" ip65="" type=""></only>				
	Weight		100g 3.527 oz (Pin type)				
			110g 3.880 oz (Screw terminal type)				

Note: 1) Unless otherwise specified, the measurement conditions at the maximum scale time standard are specified to be the rated operating voltage (within 5% ripple factor for DC), 20°C 68°F ambient temperature, and 1s power off time.

2) For the 1s range, the tolerance for each specification becomes ±10ms.

Terminal layouts and wiring diagrams



Pin type

Analog Timers

• Timed-out 1 Form C • Instantaneous 1 Form C



Part names PM4H-S



Time range selector 16 time settings selectable (1 s to 500 h) 1s 5s 10s 50s 1min 5min 10min 50min 1h 5h 10h 50h 10h 50h 100h 500h



- Screw terminal type • Timed-out 1 Form C
- Instantaneous 1 Form C
- N.C. N.O. 6 7 8 9 10 N.C. N.O.



Power indicator LED

Time indicator window

PM4H-S Pin type Screw terminal type • Timed-out 2 Form C • Timed-out 2 Form C 678910 45 `ô 3 12345 Operating voltage (+) _____Operating voltage-/ (-1) DC Type Pin Туре Connect the terminal (2) to negative PM4H-A Connect the terminal 2 to negative (–), and the terminal 1 to positive (+). (-), and the terminal (1) to positive (+) PM4H-S Connect the terminal (2) to negative PM4H-M (-), and the terminal (7) to positive (+)

2) Contact

Output indicator LED

: Pulse Flicker

SF : Signal OFF-delay

OC : Pulse One-cycle

: Pulse One-shot

: Pulse ON-flicker

OF1 : Differential ON/OFF-delay (1)

OF2 : Differential ON/OFF-delay (2)

Hand

OS

⇔ Timed-out contact Instantaneous contact

3) Voltage should not be applied to the various inputs (reset, start, and stop) of the PM4H-A multi-range timer. These inputs should be input without voltage.

Set dial Time unit indicator Operation mode indicator Operation mode selector Selectable from 8 operation modes ON : Pulse ON-delay FL Instantaneous output area FO

When the hand is in this area,

instantaneous operation starts.

PM4H-A

PM4H-M



Selectable from 5 operation modes ON : Power ON-delay FL : Power flicker FO : Power ON-flicker OS : Power One-shot OC : Power One-cycle

Operation mode selector

N.C. N.O.

Screw terminal

09/2009

PM4H-A/S/M

Dimensions

• PM4H-Screw terminal type (Flush mount)



• Panel mount dimensions (with mounting frame)

Screw terminal type



• Surface mount dimensions Pin type



• Panel cut out dimensions Standard cut out dimensions are shown

below. Use mounting frame (AT8-DA4) and rubber gasket (ATC18002).



mm inch Tolerance: ±0.5 ±.020



Pin type

Pin type



Adjacent mounting



Operation mode PM4H-A

 $\begin{pmatrix} \textbf{\texttt{*} LED lighting} & \textbf{\texttt{LED flickering}} \\ T: Setting time t_1, t_2, t_a, t_b < T t_1 + t_2 = T \end{pmatrix}$

PM4H-A		(T: Setting time t1, t2, ta, tb <t t1+t2="T)</th"></t>
Operation type	Explanation	Time chart
Pulse ON-delay	 If using a time-limit start when the power is turned on, and a reset when the power is turned off, pins (2) to (6) (screw-tightening pins (2) and (3)) should be shorted ahead of time. Turn the operation mode selector switch to the (10) position. If pins (2) to (6) (screw-tightening pins (2) and (3)) are shorted (the start input is turned on) with the power supply on, the output will go on after the set time has elapsed. If the power supply is turned off, or pins (2) to (7) (screw-tightening pins (2) to (4)) are shorted (the reset input is turned on), a reset is carried out. Note) During time-limited operation, the time-limited operation is stopped while the pins (2) to (5) (screw-tightening pins (2) to (5)) are being shorted (the stop input is on). When the pins are released, time-limited operation resumes. 	ON ON OFF ON OFF Start @ ON OFF ON ON OFF Reset @ ON OFF ON OFF ON OFF Stop @
Pulse Flicker (FL)	 If using a time-limit start when the power is turned on, and a reset when the power is turned off, pins (2) to (6) (screw-tightening pins (2) and (3)) should be shorted ahead of time. Turn the operation mode selector switch to the (1) position. When pins (2) to (2) (screw-tightening pins (2) and (3)) are shorted (the start input is turned on) with the power supply on, the limited time interval begins, and the output goes on after the set time has elapsed. After the output has gone on, it goes off when the set time has elapsed, and this process is subsequently repeated. If the power supply is turned off, or pins (2) to (7) (screw-tightening pins (2) to (4)) are shorted (the reset input is turned on), a reset is carried out. Note) During time-limited operation, the time-limited operation is stopped while the pins (2) to (5) (screw-tightening pins (2) to (5)) are being shorted (the stop input is on). When the pins are released, time-limited operation resumes. 	ON OFF ON OFF ON ON OFF ON ON OFF ON ON<
Pulse ON-flicker F0	 If using a time-limit start when the power is turned on, and a reset when the power is turned off, pins 2 to 6 (screw-tightening pins 2 and 3) should be shorted ahead of time. Turn the operation mode selector switch to the 7 position. When pins 2 to 6 (screw-tightening pins 2 and 3) are shorted (the start input is turned on) with the power supply on, the output goes on, and after the set time has elapsed, it goes off. This process is subsequently repeated. If the power supply is turned off, or pins 2 to 7 (screw-tightening pins 2 to 4) are shorted (the reset input is turned on), a reset is carried out. Note) During time-limited operation, the time-limited operation is stopped while the pins 2 to 5 (screw-tightening pins 2 to 5) are being shorted (the stop input is on). When the pins are released, time-limited operation resumes. 	ON OFF OFF
Differential ON/OFF-delay (1)	 Turn the operation mode selector switch to the (F) position. When pins (2) to (6) (screw-tightening pins (2) and (3)) are shorted (the start input is turned on) with the power supply on, the output goes on, and after the set time has elapsed, it goes off. Also, when pins (2) to (6) are released (the start input goes off), the output goes on, and after the set time has elapsed, it goes off. If the status of pins (2) to (6) (screw-tightening pins (2) and (3)) changes during the time-limit interval (the start input goes from on to off, or from off to on), the time-limit interval is restarted from the point at which the change took place. If the power supply is turned off, or pins (2) to (7) (screw-tightening pins (2) to (4)) are shorted (the reset input is turned on), a reset is carried out. Note) During time-limited operation, the time-limited operation is stopped while the pins (2) to (5) (screw-tightening pins (2) to (5)) are being shorted (the stop input is on). When the pins are released, time-limited operation resumes. 	Power supply ON OFF Start ②-③ ON OFF Start ③-③ ON OFF Reset ②-③ ON OFF Stop ②-③ ON OFF Time out (N.O. contact) OFF ON OFF OP. LED * * △ * * ∞ POWER LED * * Restart ANote: * LED lighting or No LED lighting
Signal OFF-delay SF	 Turn the operation mode selector switch to the (s) position. When pins (2) to (6) (screw-tightening pins [2] and (3)) are shorted (the start input is turned on) with the power supply on, the output goes on, and when pins (2) to (6) (screw-tightening pins [2] and (3)) are released (the start input is turned off), the time limit interval begins. After the set time has elapsed, the output goes off. If start input is entered at any point during the time limit interval is reset. Note) During time-limited operation, the time-limited operation is stopped while the pins (2) to (5) (screw-tightening pins [2] to (5)) are being shorted (the stop input is on). When the pins are released, time-limited operation resumes. 	ON OFF Start @-@ ON OFF Start @-@ ON OFF Reset @-@ ON OFF Stop @-@ ON OFF Time out (N.O. contact) ON OFF OP LED * * POWER LED * ANote: * LED lighting or No LED lighting

Note:

Keep 0.1s or more for power off time. Keep 0.05s or more for start, stop, reset input time.

PM4H-A/S/M

Operation type	Explanation	Time chart
Pulse One-shot	 If using a time-limit start when the power is turned on, and a reset when the power is turned off, pins ② to ⑥ (screw-tightening pins ② and ③) should be shorted ahead of time. Turn the operation mode selector switch to the ⑥ position. When pins ② to ⑥ (screw-tightening pins ② and ③) are shorted (the start input is turned on) with the power supply on, the output goes on for the set time limit interval. If the power supply is turned off, or pins ② to ⑦ (screw-tightening pins ② to ④) are shorted (the reset input is turned on), a reset is carried out. Note) During time-limited operation, the time-limited operation is stopped while the pins ② to ⑤ (screw-tightening pins ② to ⑤) are being shorted (the stop input is on). When the pins are released, time-limited operation resumes. 	ON OFF Start @-@ Start @-@ No OFF Reset @-@ Stop @-@ ON OFF Stop @-@ ON OFF ON OFF Stop @-@ OP. LED * POWER LED * △Note: ★ LED lighting or No LED lighting
Differential ON/OFF-delay (2) 0F2	 Turn the operation mode selector switch to the (P) position. When pins (2) to (6) (screw-tightening pins (2) and (3)) are shorted (the start input is turned on) with the power supply on, the time limit interval begins, and after the set time interval has elapsed, the output goes on. Also, when pins (2) to (6) are released (the start input goes off), the time limit interval begins, and after it has elapsed, the output goes off), the time limit interval begins, and after it has elapsed, the output goes off). If the status of pins (2) to (6) (screw-tightening pins (2) and (3)) changes during the time-limit interval (the start input goes from on to off, or from off to on), the time limit interval is restarted from the point at which the change took place. If the source upply is turned off, or pins (2) to (7) (screw-tightening pins (2) to (4)) are shorted (the reset input is turned on), a reset is carried out. Note) During time-limited operation, the time-limited operation is stopped while the pins (2) to (5) (screw-tightening pins (2) to (5)) are being shorted (the stop input is on). When the pins are released, time-limited operation resumes. 	ON OFF ON OFF Start @-@ ON OFF ON OFF Start @-@ ON OFF ON OFF Reset @-@ ON OFF ON OFF Stop @-@ ON OFF ON OFF Time out (N.O. contact) Water * * & A * * * * A * * * * A * * * * * *
Pulse One-cycle	 If using a time-limit start when the power is turned on, and a reset when the power is turned off, pins (a) to (c) (screw-tightening pins (2) and (3)) should be shorted ahead of time. Turn the operation mode selector switch to the (c) position. When pins (a) to (c) (screw-tightening pins (2) and (3)) are shorted (the start input is turned on) with the power supply on, the output goes on after the set time limit interval has elapsed. After it has gone on, it goes off after one pulse (approximately 0.8 seconds). If the power supply is turned off, or pins (a) to (c) (screw-tightening pins (2) to (4)) are shorted (the reset input is turned on), a reset is carried out. Note) During time-limited operation, the time-limited operation is stopped while the pins (c) to (c) (screw-tightening pins (2) to (c) (the stop input is on). When the pins are released, time-limited operation resumes. 	Power supply ON OFF ON OFF Start @-@ ON OFF OFF OFF Reset @-@ ON OFF ON OFF Stop @-@ ON OFF ON OFF Stop @-@ ON OFF ON OFF OP @-@ ON OFF OFF OFF OR DO OFF OFF OFF OFF OP

Note: Keep 0.1s or more for power off time.

Keep 0.05s or more for start, stop, reset input time.

PM4H-S

PM4H-S		(
Operation type Explanation		Time chart		
Power ON-delay	Time limit contact relay When the power supply is turned on, the output goes on after the set time interval has elapsed. When the power supply is turned off, a reset is carried out.	ON OFF Time out (N.O. contact) Ton OP. LED * POWER LED *		

PM4H-M

Operation type	Explanation	Time chart			
Power ON-delay ON Power Flicker FL Power ON-flicker F0 Power One-shot OS Power One-cycle OC	Turn the operation mode selector switch to display the various opera- tions. When the power supply is turned on, the time limit interval begins, and operation is carried out. When the power supply is turned off, a reset is carried out.	Power ON-delay	ON O	OFF OFF OFF	

Note:

Keep 0.1s or more for power off time. PM4H-M timers do not have each input which is start, reset and stop.